



1  
SCALE: N.T.S.  
GROUND FLOOR ELECTRICAL PLAN

P R E L I M I N A R Y  
N O T F O R C O N S T R U C T I O N

REFERENCE NOTES  
1  
DEDICATED SWITCHES AT  
GROUND FLOOR FOR MAIN  
FLOOR RECESSED LIGHTS

ELECTRICAL/MECHANICAL NOTES  
- 400 AMP SERVICE - LOCATE AND INSTALL TO LOCAL ELECTRICAL CO. SPECS SUB PANEL LOCATED PER PLANS  
- ALL RECEPTACLES LOCATED IN KITCHEN AND CLASSROOMS  
- SMOKE DETECTORS LOCATED IN HALLWAYS  
- SMOKE DETECTORS TO BE HARD WIRED W/ BATTERY BACKUP  
- PROVIDE 220 SERVICE TO RANGE, WATER HEATER, DISHWASHER, A/C, CONDENSER AND CLOTHES DRYER. PROVIDE SEPARATE 20 AMP CIRCUIT TO REFRIGERATOR AND ANY OTHER MAJOR APPLIANCES  
- EXTEND EXHAUST FANS AND KITCHEN HOOD TO EXTERIOR THRU ROOF  
- HEATING/COOLING SYSTEM TO BE INSTALLED BY LICENSED PROFESSIONAL CONTRACTOR  
- FIRE ALARM SYSTEM TO BE INSTALLED BY LICENSED PROFESSIONAL CONTRACTOR  
- ALL STROGES TO BE LOCATED IN COMPLIANCE WITH MOST RECENT NFPA AND ADA SPECIFICATIONS

ELECTRICAL LEGEND AS NEEDED

- SMOKE DETECTOR
- ⊠ EXHAUST FAN
- RECESSED LIGHT
- ⊗ TYPICAL LIGHT FIXTURE
- ⊖ GROUND FAULT OUTLET
- ⊖ 220 OUTLET
- ⊖ 110 OUTLET
- CABLE
- ⊖ SWITCH (1,2 OR 3 WAY)
- SINGLE BULB FLUORESCENT FIXTURE SURFACE MOUNTED
- 2 X 4' FLUORESCENT FIXTURES SURFACE MOUNTED
- 2 X 2 LAY IN ACoustICAL GELING
- ⊗ 2 X 4 FLUORESCENT FIXTURE

LAKESHORE BAPTIST CHURCH  
FELLOWSHIP HALL AND  
CLASSROOMS  
GROUND FLOOR ELECTRICAL PLAN

DATE: 07/28/11  
SCALE: 3/16"=1'-0"  
DRAWN BY: M. MADISON  
JOB: 2011-01

SHEET  
E1.3

I N T E G R I T Y  
designs